

ADDENDUM #3

GEORGETOWN PARK IMPROVEMENTS PROJECT

GEORGETOWN, INDIANA

Bidders are hereby notified of the following information, which is made as part of the contract documents for the above referenced project:

1. Site Improvements Bid Package:


- a. **Clarification Regarding Electric Service:** Bidders shall include in their bid all work required to furnish and install the primary electrical service to the transformer, set the transformer pad, and construct the service in accordance with Duke Energy standards. Bidders shall also provide secondary electrical service from the transformer to all electrical elements within the project limits.
- b. **Bid Form:** The following items have been modified or added to the bid form:
 - i. **Item 18 (Transformer Pad):** The transformer is not included as part of the Contractors bid. This item shall only include the installation of the concrete pad for the transformer.
 - ii. **Item 18a (NEW ITEM):** This item is for the installation of a new 200 amp panel and service. The panel shall be installed near the location of the proposed transformer pad.
 - iii. **Item 29 (Bollard Lighting):** This item shall include all conduit and power needed for each light to be installed.
 - iv. **Item 31 (Landscape Uplighting):** This item shall include all conduit and power needed for each light to be installed.
- c. A revised Bid Form is attached to this Addendum to reflect this information.

ACKNOWLEDGMENT OF THIS ADDENDUM MUST BE INCLUDED IN THE BIDDER'S PROPOSAL.

END ADDENDUM # 3

Issued: April 16, 2026

Issued by: Town of Georgetown
P.O. Box 127
9111 State Road 64
Georgetown, Indiana 47122



Robert L. Woosley Jr., P.E.
Town Engineer
Georgetown, IN